

Spill Summary Report for NRC Report #771812

Report Date: 9/14/2022

Report Time: 4:00 PM EDT

Region II Hotline Log Entry Information

Data ID: 107791

Date Of Report: 9/8/2005

NRC #: 771812

State #: 0506217

ERNS #: 184953

Material Type: Haz

Receiver: HEDE

Material / Amount:

OIL, MISC: TRANSFORMER (300 GALLON(S)); POLYCHLORINATED BIPHENYLS (0 UNKNOWN AMOUNT)

Location:

Street:
 City: MANHATTAN
 County: NEW YORK (MANHATTAN)
 State: NY
 Latitude:
 Longitude:

Source of Pollution:

CON EDISON

Water Body:

STORM DRAIN

State Or EPA Responded:

Initial EPA Action:

contacted con edison. called nydec

Status:

URL:

Associated Action Reports

DataID: 0023976

Date: 9/8/2005	Time: 13:28 EDT	
Duty Officer/Responder Name: HEDE	NRC Report #: 771812	Hotline Log DataID: 107791
Action Information		
Description: NYDEC hotline got nrc report(0506956). also they stated that there was nrc report (0506217)on the same trasformer in august 19th, 2005.for the same incident when it was leaking.EPA should investigate if con edison was negligent.		
Follup-Up:		
Person Contacted		
Name: Timothy Parker Organization: Con Edison Phone #: 212-580-6765		

NRC Spill Report

NATIONAL RESPONSE CENTER 1-800-424-8802

GOVERNMENT USE ONLYGOVERNMENT USE ONLY***

Information released to a third party shall comply with any
 applicable federal and/or state Freedom of Information and Privacy Laws

Incident Report # 771812

INCIDENT DESCRIPTION

*Report taken by: CIV NICHULUS THREATT at 12:31 on 08-SEP-05

Incident Type: FIXED

Incident Cause: EQUIPMENT FAILURE

Affected Area: STORM DRAIN

The incident was discovered on 08-SEP-05 at 12:28 local time.

Affected Medium: WATER STORM DRAIN, CONCRETE

REPORTING PARTY

Name: TIMOTHY PARKER

Organization: CON EDISON

Address: 128 WEST END AVENUE

NEW YORK, NY 10003

CON EDISON called for the responsible party.

PRIMARY Phone: (212)5806765

INCIDENT LOCATION

524 E. 74TH County: NEW YORK (MANHATTAN)

City: MANHATTAN State: NY

RELEASED MATERIAL(S)

CHRIS Code: OTF Official Material Name: OIL, MISC: TRANSFORMER

Also Known As:

Qty Released: 300 GALLON(S) Qty in Water: 0 UNKNOWN AMOUNT

CHRIS Code: PCB Official Material Name: POLYCHLORINATED BIPHENYLS

Also Known As:

Qty Released: 0 UNKNOWN AMOUNT Qty in Water: 0 UNKNOWN AMOUNT

DESCRIPTION OF INCIDENT

THE MATERIAL RELEASED FROM A PAD MOUNTED TRANSFORMER DUE TO EQUIPMENT FAILURE.
TRANSFORMER DOES CONTAIN PCB.

SENSITIVE INFORMATION

INCIDENT DETAILS

Package: N/A
Building ID:
Type of Fixed Object: TRANSFORMER
Power Generating Facility: NO
Generating Capacity:
Type of Fuel:
NPDES:
NPDES Compliance: UNKNOWN

---WATER INFORMATION---

Body of Water: STORM DRAIN
Tributary of: UNKNOWN
Nearest River Mile Marker:
Water Supply Contaminated: NO

REPORTING PARTY

Type of Organization: PRIVATE ENTERPRISE

SUSPECTED RESPONSIBLE PARTY

Name: TIMOTHY PARKER
Organization: CON EDISON
Address: 128 WEST END AVENUE
NEW YORK, NY 10003
PRIMARY Phone: (212)5806765
Type of Organization: PRIVATE ENTERPRISE

IMPACT

Fire Involved: NO Fire Extinguished: UNKNOWN
INJURIES: NO Hospitalized: Empl/Crew: Passenger:
FATALITIES: NO Empl/Crew: Passenger: Occupant:
EVACUATIONS: NO Who Evacuated: Radius/Area:
Damages: NO

		Hours	Direction of
<u>Closure Type</u>	<u>Description of Closure</u>	<u>Closed</u>	<u>Closure</u>
Air: N			
Road: N			Major Art _N
Waterway: N			
Track: N			

Passengers Transferred: NO
Environmental Impact: UNKNOWN

Media Interest: NONE Community Impact due to Material: NO

REMEDIAL ACTIONS

INVESTIGATION UNDERWAY
Release Secured: UNKNOWN
Release Rate:
Estimated Release Duration:

WEATHER

Weather: CLEAR, ⬤F

ADDITIONAL AGENCIES NOTIFIED

Federal:
State/Local:
State/Local On Scene:
State Agency Number:

NOTIFICATIONS BY NRC

ATSDR NJ ATTN: J. KOLAKOWSKI (PRIMARY)
08-SEP-05 12:34 (609)5887658
ATSDR NY (PRIMARY)
08-SEP-05 12:34 (212)6374307
DOT CRISIS MANAGEMENT CENTER (PRIMARY)
08-SEP-05 12:34 (202)3661863
U.S. EPA II (PRIMARY)
08-SEP-05 12:35 (732)3214370 HEDE
NATIONAL INFRASTRUCTURE COORD CTR (PRIMARY)

08-SEP-05 12:34 (202)2829201
NOAA 1ST CLASS BB RPTS FOR NY (PRIMARY)
08-SEP-05 12:34 (206)5266344
BUREAU TOXIC SUBSTANCE R. WILBURN (PRIMARY)
08-SEP-05 12:34 (518)4027810
ACTIVITIES NEW YORK (PRIMARY)
08-SEP-05 12:36 (718)3544353 MCCLAIN
NY STATE DEC SPILL HOTLINE (PRIMARY)
08-SEP-05 12:34 (518)4577362
NJ DEP POC: DUTY OFFICER (PRIMARY)
08-SEP-05 12:34 (609)5882848

ADDITIONAL INFORMATION

CALLER WILL NOTIFY DEC AND DEP.

*** END INCIDENT REPORT # 771812 ***

Report any problems or Fax number changes by calling 1-800-424-8802

PLEASE VISIT OUR WEB SITE AT <http://www.nrc.uscg.mil>